



Washington Suburban Sanitary Commission Collection System Discharge Written Report

9168428-118-2009

MDE OFFICIAL CONTACTED: JOAN HOHMAN

DATA CALLED IN BY: DONNA M FORREST DATE: 10/01/2009 AT 10:14PM

WORK ORDER(S): 9168428 9168345

EST DATE AND TIME SSO BEGAN: 10/01/2009 06:24PM DURATION: 2.10 HRS
DATE AND TIME SSO ENDED: 10/01/2009 08:30PM

SOURCE-OVERFLOWING MH MH05109052 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12011 VEIRS MILL RD 20906
COUNTY/PAGE/GRID: M 5285 H02 TOWN/CITY: WHEATON

CAUSE: GREASE EST OVERFLOW VOLUME: 630 GAL
UPON ARRIVAL CREW FOUND MH052M OVERFLOWING 5 GALLONS PER MINUTE INTO
STORM DRAIN. THEY JETTED THE MAINLINE AND REMOVED A GREASE BLOCKAGE
TO STOP THE OVERFLOW.

<INITIAL CAUSE=13>

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY

SIGNS POSTED: 4 POST DATE: 10/5/2009