



# Washington Suburban Sanitary Commission Collection System Discharge Written Report

9195611-118-2009

MDE OFFICIAL CONTACTED: CAROL HASSELBERGER/BECKY

DATA CALLED IN BY: SHARON R JOYNER

DATE: 10/08/2009 AT 03:37PM

WORK ORDER(S): 9195611 9195207

EST DATE AND TIME SSO BEGAN: 10/08/2009 01:55PM DURATION: 2.83 HRS  
DATE AND TIME SSO ENDED: 10/08/2009 04:45PM

SOURCE-OVERFLOWING MH MH15053212 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 25304 RIDGE RD 20871  
COUNTY/PAGE/GRID: M 4809 F07 TOWN/CITY: DAMASCUS

CAUSE: DEBRIS EST OVERFLOW VOLUME: 170 GAL  
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE 212M OVERFLOWING ABOUT 1  
GPM. A CREW JETTED FROM MANHOLE 211M TO 212M A TOTAL OF 139 FEET  
RELIEVING GRAVEL AT 12 FEET, ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER PUBLIC ACCESS  
NOTICEABLE ODOR

NO WATERWAY WAS IMPACTED.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

A WORK ORDER WAS GENERATED TO SPREAD LIME.

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 4 POST DATE: 10/08/2009