



Washington Suburban Sanitary Commission Collection System Discharge Written Report

9199530-118-2009

MDE OFFICIAL CONTACTED: JASON RAKER

DATA CALLED IN BY: AMANDA A LEWIS DATE: 10/12/2009 AT 10:25PM

WORK ORDER(S): 9199530 9199530

EST DATE AND TIME SSO BEGAN: 10/12/2009 09:03PM DURATION: 2.62 HRS
DATE AND TIME SSO ENDED: 10/12/2009 11:40PM

SOURCE-OVERFLOWING MH MH03037053 WATER BODY AFFECTED-BEAVERDAM BRANCH

CLOSEST STREET ADDRESS: 1206 ELSA AVE 20785-4313
COUNTY/PAGE/GRID: P 5530 G06 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 943 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 052M AND 053U OVERFLOWING. THE
MAINLINE WAS JETTED FROM MANHOLE 045U TO 052M, A TOTAL OF 213 FEET. A
HEAVY GREASE BLOCKAGE WAS RELIEVED AT 90 FEET ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION DRY WEATHER
PUBLIC ACCESS

LIQUID SEWAGE RAN INTO UNKNOWN TRIBUTARY TO BEAVERDAM CREEK.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE LIME

SPREAD 1 BAG OF LIME

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 4 POST DATE: 10/13/2009