



Washington Suburban Sanitary Commission Collection System Discharge Written Report

9224874-118-2009

MDE OFFICIAL CONTACTED: CARROLL HASSELBERGER

DATA CALLED IN BY: TRACY MARUCO DATE: 10/26/2009 AT 04:56PM

WORK ORDER(S): 9224874 9224726

EST DATE AND TIME SSO BEGAN: 10/26/2009 03:24PM DURATION: 2.10 HRS
DATE AND TIME SSO ENDED: 10/26/2009 05:30PM

SOURCE-OVERFLOWING MH MH14081082 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 12812 REDGRAVE DR 20774-5663
COUNTY/PAGE/GRID: P 5652 E02 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS EST OVERFLOW VOLUME: 126 GAL
THE CREW ARRIVED AND FOUND MANHOLE NUMBER 082N OVERFLOWING AND
RUNNING INTO THE STORM DRAIN. THEY JETTED FROM MANHOLE NUMBER 052U TO
081U A TOTAL OF 130 FEET, AND HIT AND RELIEVED A HEAVY ROOT STOPPAGE
ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION DRY WEATHER
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

A SMALL AMOUNT OF THE OVERFLOW ENTERED THE STORM DRAIN, NO SIGNS
NEEDED AT THE OUTFALL. THE REMAINDER WAS FLUSHED BACK INTO THE
MANHOLE.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT