



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2755528-118-2018

MDE OFFICIAL CONTACTED: KATIE

DATA CALLED IN BY: DIARRA K MACKALL DATE: 04/11/2018 AT 05:46PM

WORK ORDER(S): 2755528 2755499

EST DATE AND TIME SSO BEGAN: 04/11/2018 03:32PM DURATION: 2.97 HRS
DATE AND TIME SSO ENDED: 04/11/2018 06:30PM

SOURCE-OVERFLOWING MH MH02028005 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 1100 BROADMORE PL 20904-3110
COUNTY/PAGE/GRID: M 5167 B10 TOWN/CITY: SILVER SPRING

CAUSE: ROOTS EST OVERFLOW VOLUME: 2 GAL
UPON ARRIVAL, THE INSPECTOR FOUND SEWAGE SEEPING OUT OF MANHOLE #005M
IN THE REAR OF THE PROPERTY. THE CREW JETTED FROM MANHOLE #003U TO
MANHOLE #005M A TOTAL OF 167 FEET, HITTING AND RELIEVING ROOTS AND
RAGS AT 165 FEET, ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
PUBLIC ACCESS DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES