



# Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2757157-118-2018

MDE OFFICIAL CONTACTED: KATIE

DATA CALLED IN BY: PATRICIA A HILL DATE: 04/14/2018 AT 05:30PM

WORK ORDER(S): 2757157 2757153

EST DATE AND TIME SSO BEGAN: 04/14/2018 02:13PM DURATION: 0.45 HRS  
DATE AND TIME SSO ENDED: 04/14/2018 02:40PM

SOURCE-OVERFLOWING MH MH08055087 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 12-A RIDGE RD 20770  
COUNTY/PAGE/GRID: P 5410 J01 TOWN/CITY: GREENBELT

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 1 GAL  
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE #087U FULL AND EVIDENCE IT  
HAD OVERFLOWED A TOTAL OF ONE GALLON. THE CREW JETTED FROM MANHOLE  
#086M A TOTAL OF 145 FEET, HITTING AND RELIEVING AN UNKNOWN  
OBSTRUCTION AT 7 FEET, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
PUBLIC ACCESS DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES  
PG COUNTY HEALTH DEPT

SIGNS POSTED: 1 POST DATE: 04/14/2018