



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2797329-073-2018

MDE OFFICIAL CONTACTED: ARIANNA STANTON

DATA CALLED IN BY: DIARRA K MACKALL DATE: 08/15/2018 AT 02:38PM

WORK ORDER(S): 2797329 2797282

EST DATE AND TIME SSO BEGAN: 08/15/2018 11:00AM DURATION: 0.08 HRS
DATE AND TIME SSO ENDED: 08/15/2018 11:05AM

SOURCE-CLEAN OUT 00211903000 WATER BODY AFFECTED-MUDDY BRANCH

CLOSEST STREET ADDRESS: 9030 COMPRINT CT 20877
COUNTY/PAGE/GRID: M 5164 A01 TOWN/CITY: GAITHERSBURG

CAUSE: DEBRIS EST OVERFLOW VOLUME: 1/2 GAL
WHILE DYE TESTING THE SERVICE, THE CLEAN OUT OVERFLOWED APPROXIMATELY
1/2 GALLON. A SOFT PAPER AND DEBRIS STOPPAGE WAS RELIEVED AT 2 FEET,
AND THE EVENT ENDED.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME RAKED AREA

NOTIFICATIONS MADE:
MONTGOMERY CO MUNICIPALITIES MD DEPARTMENT OF ENVIRONMENT
DEP-MONTGOMERY COUNTY