



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2729839-118-2018

MDE OFFICIAL CONTACTED: TIM SCHNEEMAN

DATA CALLED IN BY: MARGARET K CEASAR DATE: 01/16/2018 AT 09:48PM

WORK ORDER(S): 2729839 2729797

EST DATE AND TIME SSO BEGAN: 01/16/2018 03:45PM DURATION: 4.75 HRS
DATE AND TIME SSO ENDED: 01/16/2018 08:30PM

SOURCE-OVERFLOWING MH MH10018002 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 3301 COOL SPRING RD 20783
COUNTY/PAGE/GRID: P 5409 G02 TOWN/CITY: ADELPHI

CAUSE: GREASE EST OVERFLOW VOLUME: 570 GAL
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE #002U OVERFLOWING TWO GALLONS PER MINUTE DEEP IN THE WOODS. THE CREW JETTED FROM MANHOLE #004U TO MANHOLE #065M A TOTAL OF 294 FEET, HITTING AND RELIEVING HEAVY GREASE AND PAPER AT 15 FEET, ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
NOTICEABLE ODOR PUBLIC ACCESS
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 3300 BLK R/W COOL SPRING ROAD.

SIGNS POSTED: 3 POST DATE: 01/17/2018