



# Washington Suburban Sanitary Commission

## Sanitary Sewer Overflow Written Report

2775682-118-2018

MDE OFFICIAL CONTACTED: VALERIE

DATA CALLED IN BY: BRANDON T MCCREA DATE: 06/02/2018 AT 02:45PM

WORK ORDER(S): 2775682 2775674

EST DATE AND TIME SSO BEGAN: 06/02/2018 12:00PM DURATION: 3.00 HRS  
DATE AND TIME SSO ENDED: 06/02/2018 03:00PM

SOURCE-OVERFLOWING MH MH10017072 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 8302 ROSETTE LN 20783-2258  
COUNTY/PAGE/GRID: P 5409 E02 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 900 GAL  
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE 072M OVERFLOWING LIQUID ONLY AT A RATE OF 5 GALLONS PER MINUTE, ENTERING A CREEK IN THE NORTHWEST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 008U A TOTAL OF 232 FEET, HITTING AND RELIEVING A HEAVY GREASE OBSTRUCTION AT 149 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DISCOLORATION DRY WEATHER  
NOTICEABLE ODOR PUBLIC ACCESS  
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:  
PG COUNTY HEALTH DEPT PG COUNTY MUNICIPALITIES  
MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 7 POST DATE: 06/04/2018