



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2776567-118-2018

MDE OFFICIAL CONTACTED: CATHY MOHAD

DATA CALLED IN BY: DIARRA K MACKALL DATE: 06/06/2018 AT 01:45PM

WORK ORDER(S): 2776567 2776533

EST DATE AND TIME SSO BEGAN: 06/06/2018 11:10AM DURATION: 7.83 HRS
DATE AND TIME SSO ENDED: 06/06/2018 07:00PM

SOURCE-OVERFLOWING MH MH07066028 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 8028 CINDY LN 20817
COUNTY/PAGE/GRID: M 5406 B01 TOWN/CITY: BETHESDA

CAUSE: ROOTS EST OVERFLOW VOLUME: 470 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 028M OVERFLOWING APPROXIMATELY 1 GALLON PER MINUTE INTO A NEARBY TRIBUTARY, IN THE CABIN JOHN BASIN. THE CREW HAND RODDED FROM MANHOLE 028M AND RELIEVED HEAVY ROOTS FROM MANHOLE 028M; ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

ORIGINALLY REPORTED AS 8500 RIVER ROAD.

SIGNS POSTED: 10 POST DATE: 06/07/2018