



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2809017-073-2018

MDE OFFICIAL CONTACTED: ARIANA STANTON

DATA CALLED IN BY: RITA HINES-VERRETT DATE: 10/02/2018 AT 10:13AM

WORK ORDER(S): 2809017 2808813

EST DATE AND TIME SSO BEGAN: 10/01/2018 10:27AM DURATION: 8.30 HRS
DATE AND TIME SSO ENDED: 10/01/2018 06:45PM

SOURCE-CLEAN OUT 00391667300 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 627 BRANDON GREEN DR 20904
COUNTY/PAGE/GRID: M 5166 G10 TOWN/CITY: SILVER SPRING

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 1 GAL
UPON ARRIVAL, THE WSSC CONTRACT PLUMBER FOUND THE CLEANOUT AT THE
PROPERTY LINE OVERFLOWING. THE WSSC PLUMBER SNAKED FROM THE CLEANOUT
AT THE PROPERTY LINE TO THE MAIN LINE CONNECTION, A TOTAL OF 30 FEET,
HITTING AND RELIEVING A SOFT STOPPAGE AT 20 FEET, ENDING THE
OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
DISCOLORATION

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES