



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2860858-118-2019

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: MARK A ALEXANDER DATE: 04/10/2019 AT 12:38PM

WORK ORDER(S): 2860858 2860838

EST DATE AND TIME SSO BEGAN: 04/10/2019 11:45AM DURATION: 3.00 HRS
DATE AND TIME SSO ENDED: 04/10/2019 02:45PM

SOURCE-OVERFLOWING MH MH08056061 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 9078 BALTIMORE AVE 20740-1312
COUNTY/PAGE/GRID: P 5288 B10 TOWN/CITY: COLLEGE PARK

CAUSE: GREASE EST OVERFLOW VOLUME: 180 GAL
UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE 061N OVERFLOWING AT A RATE OF ONE GALLON PER MINUTE ENTERING INTO A NEARBY STORM DRAIN IN THE NORTHEAST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 060M A TOTAL OF 72 FEET, RELIEVING A HEAVY GREASE OBSTRUCTION AT 14 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE VISIBLE SOLIDS REMOVED
NO LIME NEEDED.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 9066 BALTIMORE AVENUE.

SIGNS POSTED: 2 POST DATE: 04/11/2019