



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2861939-118-2019

MDE OFFICIAL CONTACTED: KATHIE BAKER

DATA CALLED IN BY: BRANDON T MCCREA DATE: 04/15/2019 AT 01:55PM

WORK ORDER(S): 2861939 2861921

EST DATE AND TIME SSO BEGAN: 04/15/2019 12:47PM DURATION: 3.47 HRS
DATE AND TIME SSO ENDED: 04/15/2019 04:15PM

SOURCE-OVERFLOWING MH MH09003351 WATER BODY AFFECTED-ANACOSTIA RIVER

CLOSEST STREET ADDRESS: 4016 CRITTENDEN ST 20781
COUNTY/PAGE/GRID: P 5409 J09 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE EST OVERFLOW VOLUME: 208 GAL
UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE 351M OVERFLOWING AT A RATE OF ONE GALLON PER MINUTE, ENTERING INTO A NEARBY STORM DRAIN IN THE LOWER ANACOSTIA BRANCH BASIN. THE CREW JETTED FROM MANHOLE 350M A TOTAL OF 200 FEET, RELIEVING A HARD GREASE AND RAG OBSTRUCTION AT 85 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE LIME

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY MUNICIPALITIES
PG COUNTY HEALTH DEPT

SIGNS POSTED: 2 POST DATE: 04/15/2019