



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2843945-118-2019

MDE OFFICIAL CONTACTED: JOANNE HOHMAN

DATA CALLED IN BY: ROBIN DESPANZA DATE: 02/05/2019 AT 04:15PM

WORK ORDER(S): 2843945 2843814

EST DATE AND TIME SSO BEGAN: 02/05/2019 11:32AM DURATION: 3.97 HRS
DATE AND TIME SSO ENDED: 02/05/2019 03:30PM

SOURCE-OVERFLOWING MH MH05057007 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 9606 CULVER ST 20895
COUNTY/PAGE/GRID: M 5285 G09 TOWN/CITY: KENSINGTON

CAUSE: GREASE EST OVERFLOW VOLUME: 119 GAL
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE #007M OVERFLOWING
APPROXIMATELY 0.5 GALLON PER MINUTE, ENTERING A NEARBY STORM DRAIN IN
THE ROCK CREEK BASIN. THE CREW JETTED THE MAINLINE FROM MANHOLE #008U
TO MANHOLE #007M, A TOTAL OF 244 FEET, HITTING AND RELIEVING HEAVY
GREASE INSIDE MANHOLE #007M, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

SIGNS POSTED: 7 POST DATE: 02/06/2019