



# Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2844331-118-2019

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: DIARRA K MACKALL DATE: 02/07/2019 AT 12:05PM

WORK ORDER(S): 2844331 2844305

EST DATE AND TIME SSO BEGAN: 02/07/2019 10:38AM DURATION: 1.87 HRS  
DATE AND TIME SSO ENDED: 02/07/2019 12:30PM

SOURCE-OVERFLOWING MH MH10081056 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 3700 ROSSMOOR BLVD 20906  
COUNTY/PAGE/GRID: M 5165 H04 TOWN/CITY: LEISURE WORLD

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 785 GAL  
UPON THE CREW'S ARRIVAL, MANHOLE 056M WAS OVERFLOWING APPROXIMATELY 7 GALLONS PER MINUTE INTO A NEARBY STORM DRAIN, IN THE NORTHWEST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 055U TO MANHOLE 056M, A TOTAL OF 350 FEET, RELIEVING A HEAVY GREASE, RAGS, AND ROOTS OBSTRUCTION AT 349 FEET; ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER NOTICEABLE ODOR  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME RAKED AREA  
VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 15300 MANOR VILLAGE LANE.

SIGNS POSTED: 6 POST DATE: 02/07/2019