



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2878141-118-2019

MDE OFFICIAL CONTACTED: CARROLL HASSELBERGER

DATA CALLED IN BY: MARTIA D MELVIN DATE: 06/06/2019 AT 12:00PM

WORK ORDER(S): 2878141 2878019

EST DATE AND TIME SSO BEGAN: 06/06/2019 08:19AM DURATION: 3.35 HRS
DATE AND TIME SSO ENDED: 06/06/2019 11:40AM

SOURCE-OVERFLOWING MH MH14043031 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 14501 CHURCH ST 20772
COUNTY/PAGE/GRID: P 5652 K10 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS EST OVERFLOW VOLUME: 201 GAL
UPON ARRIVAL, THE INSPECTOR FOUND MH #031M OVERFLOWING 1 GALLON PER
MINUTE INTO GRASSY AREA. THE CREW JETTED FROM MANHOLE #030U TO
MANHOLE #031M, A TOTAL OF 367 FEET; HIT AND RELIEVED ROOTS AT 365
FEET TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION PUBLIC ACCESS
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 06/06/2019