



Washington Suburban Sanitary Commission Sanitary Sewer Overflow Written Report

2907420-118-2019

MDE OFFICIAL CONTACTED: PAMELA

DATA CALLED IN BY: AMANDA A LEWIS DATE: 10/14/2019 AT 10:40PM

WORK ORDER(S): 2907420 2907412

EST DATE AND TIME SSO BEGAN: 10/14/2019 07:05PM DURATION: 3.08 HRS
DATE AND TIME SSO ENDED: 10/14/2019 10:10PM

SOURCE-OVERFLOWING MH MH18034043 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 2613 OXON RUN DR 20748-1122
COUNTY/PAGE/GRID: P 5649 F05 TOWN/CITY: TEMPLE HILLS

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 92 GAL
UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE #043M OVERFLOWING 0.5 GALLONS PER MINUTE, ENTERING A NEARBY STORM DRAIN IN THE OXON RUN BASIN. THERE WAS ALSO EVIDENCE THE CLEANOUT AT 2611 OXON RUN DRIVE HAD OVERFLOWED. THE CREW JETTED FROM MANHOLE #002U A TOTAL OF 124 FEET, RELIEVING A HARD UNKNOWN OBSTRUCTION AT 118 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT PG COUNTY MUNICIPALITIES
MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 2609 OXON RUN DRIVE.

SIGNS POSTED: 2 POST DATE: 10/15/2019