



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

2961016-073-2020

MDE OFFICIAL CONTACTED: REGAN

DATA CALLED IN BY: DIARRA K MACKALL

DATE: 05/03/2020 AT 01:36PM

WORK ORDER(S): 2961016 2961015

EST DATE AND TIME SSO BEGAN: 05/03/2020 11:28AM DURATION: 1.03 HRS

DATE AND TIME SSO ENDED: 05/03/2020 12:30PM

SOURCE-CLEAN OUT 00133581900 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 5804 ARAPAHOE DR 20745

COUNTY/PAGE/GRID: P 5765 A01 TOWN/CITY: OXON HILL

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 4 GAL

UPON ARRIVAL, THE INSPECTOR FOUND EVIDENCE THE CLEANOUT AT THE PROPERTY LINE HAD OVERFLOWED A TOTAL OF 4 GALLONS AND THE SEWAGE HAD ENTERED A NEARBY STORM DRAIN IN THE OXON RUN BASIN. THE CREW SNAKED THE SERVICE FROM THE CLEANOUT AT THE PROPERTY LINE A TOTAL OF 80 FEET, HITTING AND RELIEVING A SOFT UNKNOWN BLOCKAGE AT 80 FEET.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 1 POST DATE: 05/03/2020