



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

2966471-109-2020

MDE OFFICIAL CONTACTED: MDE.WSACOMPLIANCE@MARYLAND.GOV

DATA CALLED IN BY: KIMBERLY GILLIS DATE: 05/18/2020 AT 12:41PM

WORK ORDER(S): 2966471 2966408

EST DATE AND TIME SSO BEGAN: 05/18/2020 08:41AM DURATION: 7.97 HRS
DATE AND TIME SSO ENDED: 05/18/2020 04:39PM

SOURCE-REPAIR SEWER MAIN SS18011006 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 1903 KNOLL DR 20745
COUNTY/PAGE/GRID: P 5649 C10 TOWN/CITY: OXON HILL

CAUSE: STREAM EROSION EST OVERFLOW VOLUME: 35,865 GAL
UPON ARRIVAL, THE CREW FOUND AN EXPOSED BROKEN PIPE AT A CREEK
CROSSING, IN A HEAVILY WOODED AREA, LEAKING 75 GALLONS PER MINUTE
INTO THE CREEK IN THE OXON RUN BASIN. A WSSC WATER CONTRACTOR SET UP
OVERPUMPING TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION DRY WEATHER
VISIBLE SOLIDS, IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

OVERPUMPING WILL REMAIN IN PLACE UNTIL PIPE REPAIRS ARE COMPLETE.
ONCE REPAIRS ARE COMPLETE, A CCTV INSPECTION WILL BE PERFORMED.

06/29/2020 UPDATE - REPAIRS WERE COMPLETED 06/07/2020 AND OVERPUMPING
HAS BEEN REMOVED. A CCTV INSPECTION HAS BEEN PERFORMED.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT	PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES	RADIO STATIONS
TELEVISION	NEWSPAPER

ORIGINALLY REPORTED AS 1500 MYSTIC AVENUE.
A MEDIA ADVISORY WAS ISSUED ON 05/18/2020.

SIGNS POSTED: 6 POST DATE: 05/18/2020