



NOTES:

1. USE INSULATORS ON 1", 1 1/2", AND 2" COPPER PIPE HOUSE CONNECTIONS.
2. USE INSULATOR ON COPPER PIPE TAPPED ON CAST IRON OR DUCTILE IRON PIPES,

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: \_\_\_\_\_

8/12/16

Chief Engineer

STANDARD DETAIL

INSULATED JOINT  
FOR COPPER PIPE SERVICE  
CONNECTIONS (2" OR LESS)

C  
3.5