


**NOTES:**

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE, SEE DETAIL C/7.13.
2. DO NOT THERMITE WELD TO PVC PIPE.
3. BOND ALL JOINTS ON DIP, SEE DETAILS C/1.0 AND C/1.6.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 9/29/16  
  
Chief Engineer

STANDARD DETAIL  
PVC AWWA C-900 PIPE  
ANODE PROTECTION FOR  
FIRE HYDRANT LEAD PIPE

C  
7.8