

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
1st Quarter 2019	Potomac WFP ^a Tap	NS	NS	NS	2.4
	Patuxent WFP ^a Tap	NS	NS	NS	ND
	Accokeek ^c	22	10	32	NS
	Brookeville ^c	23	11	33	NS
	Cedar Heights ^c	24	11	34	NS
	Central Ave ^c	20	10	30	NS
	Forest Heights ^c	27	12	38	NS
	Glenmont ^c	16	8	23	NS
	Gwynn Park ^c	21	10	30	NS
	High Bridge ^c	17	9	25	NS
	Kettering ^c	22	11	32	NS
	Montgomery ^c	18	10	27	NS
	Piscataway ^c	23	11	33	NS
	Pointer Ridge	21	11	31	NS
	Rosaryville Estates ^c	19	11	29	NS
	Tantallon ^c	22	11	32	NS
	Upper Marlboro ^c	21	10	30	NS
	Woodfield ^c	25	11	35	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>0.4</i>
	<i>Published Health Guidance or Reference Level</i>	<i>60^d</i>	<i>n/a</i>	<i>n/a</i>	<i>300^e</i>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
2nd Quarter 2019	Potomac WFP ^a Tap	NS	NS	NS	33
	Patuxent WFP ^a Tap	NS	NS	NS	0.49
	Accokeek ^c	51	13	63	NS
	Brookeville ^c	47	14	60	NS
	Cedar Heights ^c	54	14	67	NS
	Central Ave ^c	46	12	57	NS
	Forest Heights ^c	53	13	66	NS
	Glenmont ^c	49	13	61	NS
	Gwynn Park ^c	48	13	60	NS
	High Bridge ^c	37	10	48	NS
	Kettering ^c	48	12	60	NS
	Montgomery ^c	37	13	49	NS
	Piscataway ^c	45	13	57	NS
	Pointer Ridge	42	11	52	NS
	Rosaryville Estates ^c	44	12	56	NS
	Tantallon ^c	50	13	62	NS
	Upper Marlboro ^c	49	12	60	NS
Woodfield ^c	51	14	64	NS	
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory