

## Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
<b>1st Quarter 2019</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	2.4
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	ND
	Accokeek <sup>c</sup>	22	10	32	NS
	Brookeville <sup>c</sup>	23	11	33	NS
	Cedar Heights <sup>c</sup>	24	11	34	NS
	Central Ave <sup>c</sup>	20	10	30	NS
	Forest Heights <sup>c</sup>	27	12	38	NS
	Glenmont <sup>c</sup>	16	8	23	NS
	Gwynn Park <sup>c</sup>	21	10	30	NS
	High Bridge <sup>c</sup>	17	9	25	NS
	Kettering <sup>c</sup>	22	11	32	NS
	Montgomery <sup>c</sup>	18	10	27	NS
	Piscataway <sup>c</sup>	23	11	33	NS
	Pointer Ridge <sup>c</sup>	21	11	31	NS
	Rosaryville Estates <sup>c</sup>	19	11	29	NS
	Tantallon <sup>c</sup>	22	11	32	NS
	Upper Marlboro <sup>c</sup>	21	10	30	NS
Woodfield <sup>c</sup>	25	11	35	NS	
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>0.4</i>
	<i>Published Health Guidance or Reference Level</i>	<i>60<sup>d</sup></i>	<i>n/a</i>	<i>n/a</i>	<i>300<sup>e</sup></i>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

## Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
<b>2nd Quarter 2019</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	33
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	0.49
	Accokeek <sup>c</sup>	51	13	63	NS
	Brookeville <sup>c</sup>	47	14	60	NS
	Cedar Heights <sup>c</sup>	54	14	67	NS
	Central Ave <sup>c</sup>	46	12	57	NS
	Forest Heights <sup>c</sup>	53	13	66	NS
	Glenmont <sup>c</sup>	49	13	61	NS
	Gwynn Park <sup>c</sup>	48	13	60	NS
	High Bridge <sup>c</sup>	37	10	48	NS
	Kettering <sup>c</sup>	48	12	60	NS
	Montgomery <sup>c</sup>	37	13	49	NS
	Piscataway <sup>c</sup>	45	13	57	NS
	Pointer Ridge <sup>c</sup>	42	11	52	NS
	Rosaryville Estates <sup>c</sup>	44	12	56	NS
	Tantallon <sup>c</sup>	50	13	62	NS
	Upper Marlboro <sup>c</sup>	49	12	60	NS
	Woodfield <sup>c</sup>	51	14	64	NS
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 <sup>d</sup>	n/a	n/a	300 <sup>e</sup>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

## Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
<b>3rd Quarter 2019</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	3.8
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	1.0
	Accokeek <sup>c</sup>	25	14	39	NS
	Brookeville <sup>c</sup>	30	17	46	NS
	Cedar Heights <sup>c</sup>	35	19	53	NS
	Central Ave <sup>c</sup>	28	17	44	NS
	Forest Heights <sup>c</sup>	35	16	50	NS
	Glenmont <sup>c</sup>	31	18	48	NS
	Gwynn Park <sup>c</sup>	30	16	45	NS
	High Bridge <sup>c</sup>	30	18	47	NS
	Kettering <sup>c</sup>	32	18	49	NS
	Montgomery <sup>c</sup>	31	18	48	NS
	Piscataway <sup>c</sup>	32	17	48	NS
	Pointer Ridge <sup>c</sup>	36	18	53	NS
	Rosaryville Estates <sup>c</sup>	30	18	46	NS
	Tantallon <sup>c</sup>	26	13	39	NS
	Upper Marlboro <sup>c</sup>	24	14	37	NS
	Woodfield <sup>c</sup>	27	16	42	NS
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>0.4</i>
	<i>Published Health Guidance or Reference Level</i>	<i>60<sup>d</sup></i>	<i>n/a</i>	<i>n/a</i>	<i>300<sup>e</sup></i>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

## Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
<b>4th Quarter 2019</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	0.4
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	0.5
	Accokeek <sup>c</sup>	48	14	61	NS
	Brookeville <sup>c</sup>	47	14	60	NS
	Cedar Heights <sup>c</sup>	45	15	59	NS
	Central Ave <sup>c</sup>	34	12	46	NS
	Forest Heights <sup>c</sup>	48	14	60	NS
	Glenmont <sup>c</sup>	43	13	55	NS
	Gwynn Park <sup>c</sup>	49	14	62	NS
	High Bridge <sup>c</sup>	43	13	55	NS
	Kettering <sup>c</sup>	47	13	59	NS
	Montgomery <sup>c</sup>	41	13	53	NS
	Piscataway <sup>c</sup>	46	14	59	NS
	Pointer Ridge <sup>c</sup>	48	14	61	NS
	Rosaryville Estates <sup>c</sup>	39	12	51	NS
	Tantallon <sup>c</sup>	43	13	56	NS
	Upper Marlboro <sup>c</sup>	49	14	62	NS
	Woodfield <sup>c</sup>	45	14	58	NS
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 <sup>d</sup>	n/a	n/a	300 <sup>e</sup>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

## Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
<b>1st Quarter 2020</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	1.1
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	ND
	Accokeek <sup>c</sup>	36	14	49	NS
	Brookeville <sup>c</sup>	32	14	45	NS
	Cedar Heights <sup>c</sup>	31	15	45	NS
	Central Ave <sup>c</sup>	28	11	38	NS
	Forest Heights <sup>c</sup>	34	13	46	NS
	Glenmont <sup>c</sup>	33	14	46	NS
	Gwynn Park <sup>c</sup>	33	13	45	NS
	High Bridge <sup>c</sup>	28	11	39	NS
	Kettering <sup>c</sup>	34	12	45	NS
	Montgomery <sup>c</sup>	27	12	38	NS
	Piscataway <sup>c</sup>	29	12	40	NS
	Pointer Ridge <sup>c</sup>	32	14	45	NS
	Rosaryville Estates <sup>c</sup>	28	11	38	NS
	Tantallon <sup>c</sup>	31	13	43	NS
	Upper Marlboro <sup>c</sup>	35	12	46	NS
	Woodfield <sup>c</sup>	37	16	52	NS
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 <sup>d</sup>	n/a	n/a	300 <sup>e</sup>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

## Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
<b>2nd Quarter 2020</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	ND	63
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	2.2	0.57
	Accokeek <sup>c</sup>	37	11	47	NS	NS
	Brookeville <sup>c</sup>	36	12	47	NS	NS
	Cedar Heights <sup>c</sup>	37	12	48	NS	NS
	Central Ave <sup>c</sup>	31	11	41	NS	NS
	Forest Heights <sup>c</sup>	37	12	48	NS	NS
	Glenmont <sup>c</sup>	28	10	37	NS	NS
	Gwynn Park <sup>c</sup>	37	12	48	NS	NS
	High Bridge <sup>c</sup>	33	10	42	NS	NS
	Kettering <sup>c</sup>	36	11	46	NS	NS
	Montgomery <sup>c</sup>	32	10	41	NS	NS
	Piscataway <sup>c</sup>	36	12	47	NS	NS
	Pointer Ridge <sup>c</sup>	33	11	43	NS	NS
	Rosaryville Estates <sup>c</sup>	32	11	42	NS	NS
	Tantallon <sup>c</sup>	36	12	47	NS	NS
	Upper Marlboro <sup>c</sup>	36	12	46	NS	NS
Woodfield <sup>c</sup>	37	12	48	NS	NS	
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	0.4
	<i>Published Health Guidance or Reference Level</i>	60 <sup>d</sup>	n/a	n/a	700 <sup>f</sup>	300 <sup>e</sup>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

<sup>f</sup> EPA CCL4 Health Reference Level

## Unregulated Contaminants

Location		HAA5	HAA6Br	HAA9	1-butanol	Manganese
<b>3rd Quarter 2020</b>	Potomac WFP <sup>a</sup> Tap	NS	NS	NS	ND	1.8
	Patuxent WFP <sup>a</sup> Tap	NS	NS	NS	ND	0.78
	Accokeek <sup>c</sup>	37	10	47	NS	NS
	Brookeville <sup>c</sup>	73	14	86	NS	NS
	Cedar Heights <sup>c</sup>	51	14	64	NS	NS
	Central Ave <sup>c</sup>	57	16	72	NS	NS
	Forest Heights <sup>c</sup>	73	15	87	NS	NS
	Glenmont <sup>c</sup>	49	15	63	NS	NS
	Gwynn Park <sup>c</sup>	54	11	64	NS	NS
	High Bridge <sup>c</sup>	64	14	78	NS	NS
	Kettering <sup>c</sup>	66	15	79	NS	NS
	Montgomery <sup>c</sup>	53	16	68	NS	NS
	Piscataway <sup>c</sup>	50	11	61	NS	NS
	Pointer Ridge <sup>c</sup>	47	10	57	NS	NS
	Rosaryville Estates <sup>c</sup>	67	12	78	NS	NS
	Tantallon <sup>c</sup>	31	8	39	NS	NS
	Upper Marlboro <sup>c</sup>	48	10	58	NS	NS
	Woodfield <sup>c</sup>	70	15	85	NS	NS
	<i>unit of measure</i>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>	µg/L <sup>b</sup>
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	0.4
	<i>Published Health Guidance or Reference Level</i>	60 <sup>d</sup>	n/a	n/a	700 <sup>f</sup>	300 <sup>e</sup>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

### NOTES

<sup>a</sup> Water treatment plant finished water sample

<sup>b</sup> µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

<sup>c</sup> Distribution sampling site

<sup>d</sup> EPA maximum contaminant level based on highest locational running annual average

<sup>e</sup> EPA lifetime health advisory

<sup>f</sup> EPA CCL4 Health Reference Level