



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3037990-073-2021

MDE OFFICIAL CONTACTED: MARK BELL

DATA CALLED IN BY: MARK A ALEXANDER DATE: 03/08/2021 AT 06:26PM

WORK ORDER(S): 3037990 3037961

EST DATE AND TIME SSO BEGAN: 03/08/2021 04:06PM DURATION: 1.23 HRS
DATE AND TIME SSO ENDED: 03/08/2021 05:20PM

SOURCE-CLEAN OUT 00456987700 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 14815 DEMOTTE PL 20774
COUNTY/PAGE/GRID: P 5533 A09 TOWN/CITY: SPRINGDALE

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 1 GAL
UPON ARRIVAL, THE INSPECTOR FOUND EVIDENCE THE CLEANOUT AT THE
PROPERTY LINE HAD OVERFLOWED 1 GALLON. A WSSC WATER CONTRACT PLUMBER
SNAKED FROM THE CLEANOUT AT THE PROPERTY LINE, A TOTAL OF 60
FEET, HITTING AND RELIEVING A HARD UNKNOWN OBSTRUCTION AT 10 FEET.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME RAKED AREA

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES