



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3046407-118-2021

MDE OFFICIAL CONTACTED: REGAN MERCER

DATA CALLED IN BY: DON O DARKO

DATE: 04/16/2021 AT 08:30PM

WORK ORDER(S): 3046407 3046403

EST DATE AND TIME SSO BEGAN: 04/16/2021 07:55PM DURATION: 1.92 HRS

DATE AND TIME SSO ENDED: 04/16/2021 09:50PM

SOURCE-OVERFLOWING MH MH05075111 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 10681-87 WEYMOUTH ST 20896

COUNTY/PAGE/GRID: M 5285 F06 TOWN/CITY: BETHESDA

CAUSE: GREASE EST OVERFLOW VOLUME: 115 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 111M OVERFLOWING INTO A NEARBY STORM DRAIN IN THE ROCK CREEK BASIN. THE CREW JETTED FROM MANHOLE 010M TO 111M, A TOTAL OF 270FT, AND RELIEVED A HEAVY GREASE OBSTRUCTION AT 90FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

LIME

LIME WAS APPLIED TO IMPACTED GRASS AREAS.

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 8 POST DATE: 04/16/2021