



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3048838-118-2021

MDE OFFICIAL CONTACTED: CAROL HASSELBERGER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 05/03/2021 AT 11:38AM

WORK ORDER(S): 3048838 3048792

EST DATE AND TIME SSO BEGAN: 05/03/2021 09:30AM DURATION: 3.50 HRS

DATE AND TIME SSO ENDED: 05/03/2021 01:00PM

SOURCE-OVERFLOWING MH MH10012027 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 6802-7021 HIGHVIEW TER 20782

COUNTY/PAGE/GRID: P 5409 F05 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 420 GAL

UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE 027M OVERFLOWING AT A RATE OF 2 GALLONS PER MINUTE, ENTERING A NEARBY CREEK IN THE NORTHWEST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 004U A TOTAL OF 375 FEET, RELIEVING HARD GREASE AND WIPES AT 125 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 7000 BLK RW HIGHVIEW TERRACE.

SIGNS POSTED: 5 POST DATE: 05/03/2021