



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3054703-073-2021

MDE OFFICIAL CONTACTED: KENDRA DUKES 119503

DATA CALLED IN BY: KEVIN M GILLIAM DATE: 05/15/2021 AT 08:08PM

WORK ORDER(S): 3054703 3054683

EST DATE AND TIME SSO BEGAN: 05/14/2021 06:07PM DURATION: 1.22 HRS
DATE AND TIME SSO ENDED: 05/14/2021 07:20PM

SOURCE-CLEAN OUT 00118768100 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 8628 CENTRAL AVE 20785
COUNTY/PAGE/GRID: P 5531 C08 TOWN/CITY: LANDOVER

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 30 GAL

UPON ARRIVAL, THE INSPECTOR FOUND EVIDENCE THE CLEANOUT AT THE PROPERTY LINE HAD OVERFLOWED A TOTAL OF 30 GALLONS. THE CUSTOMER WAS ADVISED TO STOP USING WATER, ENDING THE EVENT. A WSSC WATER CONTRACT PLUMBER SNAKED FROM THE CLEANOUT AT THE PROPERTY LINE A TOTAL OF 60 FEET, HITTING AND RELIEVING AN UNKNOWN OBSTRUCTION AT 13 FEET.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
PUBLIC ACCESS DRY WEATHER

NO STORM DRAIN OR WATERWAY WAS AFFECTED.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME RAKED AREA
VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:
PG COUNTY MUNICIPALITIES MD DEPARTMENT OF ENVIRONMENT
PG COUNTY HEALTH DEPT