



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3056765-118-2021

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: MARVIN BAILEY DATE: 05/24/2021 AT 01:30PM

WORK ORDER(S): 3056765 3056743

EST DATE AND TIME SSO BEGAN: 05/24/2021 11:41AM DURATION: 3.65 HRS
DATE AND TIME SSO ENDED: 05/24/2021 03:20PM

SOURCE-OVERFLOWING MH MH10012027 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 6802-7021 HIGHVIEW TER 20782
COUNTY/PAGE/GRID: P 5409 F05 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 438 GAL
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE #027M OVERFLOWING 2 GALLONS PER MINUTE, ENTERING A NEARBY CREEK IN THE NORTHWEST BRANCH BASIN. THE CREW JETTED FROM MANHOLE #004U TO MANHOLE #027M A TOTAL OF 377 FEET, HITTING AND RELIEVING HEAVY GREASE AND WIPES AT 130 FEET, ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
NOTICEABLE ODOR PUBLIC ACCESS
WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:
PG COUNTY MUNICIPALITIES PG COUNTY HEALTH DEPT
MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 7000 BLK RW HIGHVIEW TERRACE.

SIGNS POSTED: 8 POST DATE: 05/24/2021