



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3056795-118-2021

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: JAMES V MALLORY

DATE: 05/24/2021 AT 03:55PM

WORK ORDER(S): 3056795 3056771

EST DATE AND TIME SSO BEGAN: 05/24/2021 01:43PM DURATION: 3.28 HRS

DATE AND TIME SSO ENDED: 05/24/2021 05:00PM

SOURCE-OVERFLOWING MH MH05174044 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 3712 TODDSBURY LN 20832

COUNTY/PAGE/GRID: M 5049 H05 TOWN/CITY: OLNEY

CAUSE: GREASE EST OVERFLOW VOLUME: 197 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 044M OVERFLOWING 1 GALLON PER MINUTE, ENTERING A STORM DRAIN, WHICH DISCHARGES INTO A CREEK IN THE ROCK CREEK BASIN. THE CREW JETTED FROM THE LOWER MANHOLE 026U TO MANHOLE 044M, HITTING AND RELIEVING HEAVY GREASE 1 FOOT UPSTREAM OF MANHOLE 043U, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

NOTICEABLE ODOR

WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT  
DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 18401 DUTCHESS DRIVE AND 3812 OLNEY LAYTONSVILLE ROAD.

SIGNS POSTED: 5 POST DATE: 05/24/2021