



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3059880-118-2021

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: DIARRA K MACKALL DATE: 06/08/2021 AT 09:44AM

WORK ORDER(S): 3059880 3059842

EST DATE AND TIME SSO BEGAN: 06/08/2021 06:43AM DURATION: 4.78 HRS
DATE AND TIME SSO ENDED: 06/08/2021 11:30AM

SOURCE-OVERFLOWING MH MH10015132 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 3100 GUMWOOD DR 20783-1928
COUNTY/PAGE/GRID: P 5409 F04 TOWN/CITY: HYATTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 1,147 GAL
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE 132M OVERFLOWING 4 GALLONS
PER MINUTE, ENTERING THE NORTHWEST BRANCH OF THE ANACOSTIA RIVER IN
THE NORTHWEST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 018U
DOWNSTREAM THROUGH 017M, 132M, AND 131M TO MANHOLE 002U A TOTAL OF 532
FEET, HITTING AND RELIEVING MEDIUM GREASE AND WIPES, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
PG COUNTY MUNICIPALITIES PG COUNTY HEALTH DEPT
MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 3102 GUMWOOD DRIVE.

SIGNS POSTED: 6 POST DATE: 06/08/2021