



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3061780-073-2021

MDE OFFICIAL CONTACTED: C ZAMERSKI

DATA CALLED IN BY: ELBE L DAVIS

DATE: 06/18/2021 AT 03:35PM

WORK ORDER(S): 3061780 3061591

EST DATE AND TIME SSO BEGAN: 06/17/2021 06:54PM DURATION: 2.18 HRS

DATE AND TIME SSO ENDED: 06/17/2021 09:05PM

SOURCE-CLEAN OUT 00201740800 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 11606 MAGRUDER LN 20852

COUNTY/PAGE/GRID: M 5284 H03 TOWN/CITY: ROCKVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 5 GAL

UPON ARRIVAL, THE CREW FOUND EVIDENCE THE PROPERTY-LINE CLEANOUT HAD RECENTLY OVERFLOWED APPROXIMATELY 5 GALLONS OF LIQUID SEWAGE. THE CREW RODDED THE SEWER SERVICE FROM MANHOLE 049M A TOTAL OF 23 FEET, AND RELIEVED ROOTS AT 20 FEET OFF PROPERTY, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 3 POST DATE: 06/18/2021