



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3065559-118-2021

MDE OFFICIAL CONTACTED: PAUL

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 07/06/2021 AT 03:00PM

WORK ORDER(S): 3065559 3065506

EST DATE AND TIME SSO BEGAN: 07/06/2021 09:30AM DURATION: 5.00 HRS

DATE AND TIME SSO ENDED: 07/06/2021 02:30PM

SOURCE-OVERFLOWING MH MH05990119 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 8404 COLESVILLE RD 20910

COUNTY/PAGE/GRID: M 5408 F01 TOWN/CITY: SILVER SPRING

CAUSE: DEBRIS EST OVERFLOW VOLUME: 300 GAL

UPON ARRIVAL THE CREWS FOUND MANHOLE 119U OVERFLOWING, APPROXIMATELY 1GPM, INTO A NEARBY STORM DRAIN IN THE ROCK CREEK BASIN. THE CREW JETTED FROM MANHOLE 118M AND RELIEVED AN UNKNOWN STOPPAGE AT APPROXIMATELY 55 FEET; ENDING THE OVERFLOW. MANHOLE 119U BEGAN SURCHARGING AND A LARGE ROCK WAS RETRIEVED FROM THE CHANNEL IN MH119U.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

VISIBLE SOLIDS REMOVED

LIME WAS APPLIED TO IMPACTED GROUND AREAS.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 07/07/2021