



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3067846-073-2021

MDE OFFICIAL CONTACTED: JOANN HOHMAN

DATA CALLED IN BY: MARK A ALEXANDER

DATE: 07/20/2021 AT 01:04AM

WORK ORDER(S): 3067846 3067841

EST DATE AND TIME SSO BEGAN: 07/19/2021 06:33PM DURATION: 0.00 HRS

DATE AND TIME SSO ENDED: 07/19/2021 06:33PM

SOURCE-ON-SITE MANHOLE 00001513100 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 9901-83 GOOD LUCK RD 20706

COUNTY/PAGE/GRID: P 5411 G02 TOWN/CITY: LANHAM-SEABROOK

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 10 GAL

UPON ARRIVAL, THE INSPECTOR FOUND EVIDENCE AN ON-SITE MANHOLE HAD OVERFLOWED A TOTAL OF TEN GALLONS AND MANHOLES 215M AND 029M WERE BACKED UP. THE CREW JETTED FROM MANHOLE 028M A TOTAL OF 268 FEET, RELIEVING A GREASE AND WIPES OBSTRUCTION, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 9901 GOOD LUCK ROAD.