

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
1st Quarter 2019	Potomac WFP ^a Tap	NS	NS	NS	2.4
	Patuxent WFP ^a Tap	NS	NS	NS	ND
	Accokeek ^c	22	10	32	NS
	Brookeville ^c	23	11	33	NS
	Cedar Heights ^c	24	11	34	NS
	Central Ave ^c	20	10	30	NS
	Forest Heights ^c	27	12	38	NS
	Glenmont ^c	16	8	23	NS
	Gwynn Park ^c	21	10	30	NS
	High Bridge ^c	17	9	25	NS
	Kettering ^c	22	11	32	NS
	Montgomery ^c	18	10	27	NS
	Piscataway ^c	23	11	33	NS
	Pointer Ridge ^c	21	11	31	NS
	Rosaryville Estates ^c	19	11	29	NS
	Tantallon ^c	22	11	32	NS
	Upper Marlboro ^c	21	10	30	NS
	Woodfield ^c	25	11	35	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
2nd Quarter 2019	Potomac WFP ^a Tap	NS	NS	NS	33
	Patuxent WFP ^a Tap	NS	NS	NS	0.49
	Accokeek ^c	51	13	63	NS
	Brookeville ^c	47	14	60	NS
	Cedar Heights ^c	54	14	67	NS
	Central Ave ^c	46	12	57	NS
	Forest Heights ^c	53	13	66	NS
	Glenmont ^c	49	13	61	NS
	Gwynn Park ^c	48	13	60	NS
	High Bridge ^c	37	10	48	NS
	Kettering ^c	48	12	60	NS
	Montgomery ^c	37	13	49	NS
	Piscataway ^c	45	13	57	NS
	Pointer Ridge ^c	42	11	52	NS
	Rosaryville Estates ^c	44	12	56	NS
	Tantallon ^c	50	13	62	NS
	Upper Marlboro ^c	49	12	60	NS
	Woodfield ^c	51	14	64	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
3rd Quarter 2019	Potomac WFP ^a Tap	NS	NS	NS	3.8
	Patuxent WFP ^a Tap	NS	NS	NS	1.0
	Accokeek ^c	25	14	39	NS
	Brookeville ^c	30	17	46	NS
	Cedar Heights ^c	35	19	53	NS
	Central Ave ^c	28	17	44	NS
	Forest Heights ^c	35	16	50	NS
	Glenmont ^c	31	18	48	NS
	Gwynn Park ^c	30	16	45	NS
	High Bridge ^c	30	18	47	NS
	Kettering ^c	32	18	49	NS
	Montgomery ^c	31	18	48	NS
	Piscataway ^c	32	17	48	NS
	Pointer Ridge ^c	36	18	53	NS
	Rosaryville Estates ^c	30	18	46	NS
	Tantallon ^c	26	13	39	NS
	Upper Marlboro ^c	24	14	37	NS
	Woodfield ^c	27	16	42	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>0.4</i>
	<i>Published Health Guidance or Reference Level</i>	<i>60^d</i>	<i>n/a</i>	<i>n/a</i>	<i>300^e</i>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
4th Quarter 2019	Potomac WFP ^a Tap	NS	NS	NS	0.4
	Patuxent WFP ^a Tap	NS	NS	NS	0.5
	Accokeek ^c	48	14	61	NS
	Brookeville ^c	47	14	60	NS
	Cedar Heights ^c	45	15	59	NS
	Central Ave ^c	34	12	46	NS
	Forest Heights ^c	48	14	60	NS
	Glenmont ^c	43	13	55	NS
	Gwynn Park ^c	49	14	62	NS
	High Bridge ^c	43	13	55	NS
	Kettering ^c	47	13	59	NS
	Montgomery ^c	41	13	53	NS
	Piscataway ^c	46	14	59	NS
	Pointer Ridge ^c	48	14	61	NS
	Rosaryville Estates ^c	39	12	51	NS
	Tantallon ^c	43	13	56	NS
	Upper Marlboro ^c	49	14	62	NS
	Woodfield ^c	45	14	58	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>0.4</i>
	<i>Published Health Guidance or Reference Level</i>	<i>60^d</i>	<i>n/a</i>	<i>n/a</i>	<i>300^e</i>

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	Manganese
1st Quarter 2020	Potomac WFP ^a Tap	NS	NS	NS	1.1
	Patuxent WFP ^a Tap	NS	NS	NS	ND
	Accokeek ^c	36	14	49	NS
	Brookeville ^c	32	14	45	NS
	Cedar Heights ^c	31	15	45	NS
	Central Ave ^c	28	11	38	NS
	Forest Heights ^c	34	13	46	NS
	Glenmont ^c	33	14	46	NS
	Gwynn Park ^c	33	13	45	NS
	High Bridge ^c	28	11	39	NS
	Kettering ^c	34	12	45	NS
	Montgomery ^c	27	12	38	NS
	Piscataway ^c	29	12	40	NS
	Pointer Ridge ^c	32	14	45	NS
	Rosaryville Estates ^c	28	11	38	NS
	Tantallon ^c	31	13	43	NS
	Upper Marlboro ^c	35	12	46	NS
	Woodfield ^c	37	16	52	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
2nd Quarter 2020	Potomac WFP ^a Tap	NS	NS	NS	ND	63
	Patuxent WFP ^a Tap	NS	NS	NS	2.2	0.57
	Accokeek ^c	37	11	47	NS	NS
	Brookeville ^c	36	12	47	NS	NS
	Cedar Heights ^c	37	12	48	NS	NS
	Central Ave ^c	31	11	41	NS	NS
	Forest Heights ^c	37	12	48	NS	NS
	Glenmont ^c	28	10	37	NS	NS
	Gwynn Park ^c	37	12	48	NS	NS
	High Bridge ^c	33	10	42	NS	NS
	Kettering ^c	36	11	46	NS	NS
	Montgomery ^c	32	10	41	NS	NS
	Piscataway ^c	36	12	47	NS	NS
	Pointer Ridge ^c	33	11	43	NS	NS
	Rosaryville Estates ^c	32	11	42	NS	NS
	Tantallon ^c	36	12	47	NS	NS
	Upper Marlboro ^c	36	12	46	NS	NS
	Woodfield ^c	37	12	48	NS	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	700 ^f	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

^f EPA CCL4 Health Reference Level

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
3rd Quarter 2020	Potomac WFP ^a Tap	NS	NS	NS	ND	1.8
	Patuxent WFP ^a Tap	NS	NS	NS	ND	0.78
	Accokeek ^c	37	10	47	NS	NS
	Brookeville ^c	73	14	86	NS	NS
	Cedar Heights ^c	51	14	64	NS	NS
	Central Ave ^c	57	16	72	NS	NS
	Forest Heights ^c	73	15	87	NS	NS
	Glenmont ^c	49	15	63	NS	NS
	Gwynn Park ^c	54	11	64	NS	NS
	High Bridge ^c	64	14	78	NS	NS
	Kettering ^c	66	15	79	NS	NS
	Montgomery ^c	53	16	68	NS	NS
	Piscataway ^c	50	11	61	NS	NS
	Pointer Ridge ^c	47	10	57	NS	NS
	Rosaryville Estates ^c	67	12	78	NS	NS
	Tantallon ^c	31	8	39	NS	NS
	Upper Marlboro ^c	48	10	58	NS	NS
	Woodfield ^c	70	15	85	NS	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	700 ^f	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

^f EPA CCL4 Health Reference Level

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
4th Quarter 2020	Potomac WFP ^a Tap	NS	NS	NS	ND	0.67
	Patuxent WFP ^a Tap	NS	NS	NS	ND	ND
	Accokeek ^c	36	8.3	44	NS	NS
	Brookeville ^c	36	12	48	NS	NS
	Cedar Heights ^c	22	11	32	NS	NS
	Central Ave ^c	24	9.7	33	NS	NS
	Forest Heights ^c	34	9.3	43	NS	NS
	Glenmont ^c	20	19	35	NS	NS
	Gwynn Park ^c	33	9.9	43	NS	NS
	High Bridge ^c	30	7.6	38	NS	NS
	Kettering ^c	33	10	42	NS	NS
	Montgomery ^c	26	12	38	NS	NS
	Piscataway ^c	39	10	49	NS	NS
	Pointer Ridge ^c	26	8	34	NS	NS
	Rosaryville Estates ^c	35	9.6	45	NS	NS
	Tantallon ^c	35	9.0	44	NS	NS
	Upper Marlboro ^c	36	10	46	NS	NS
	Woodfield ^c	34	11	44	NS	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	700 ^f	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

^f EPA CCL4 Health Reference Level

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
4th Quarter 2020	Potomac WFP ^a Tap	NS	NS	NS	ND	0.67
	Patuxent WFP ^a Tap	NS	NS	NS	ND	ND
	Accokeek ^c	36	8.3	44	NS	NS
	Brookeville ^c	36	12	48	NS	NS
	Cedar Heights ^c	22	11	32	NS	NS
	Central Ave ^c	24	9.7	33	NS	NS
	Forest Heights ^c	34	9.3	43	NS	NS
	Glenmont ^c	20	19	35	NS	NS
	Gwynn Park ^c	33	9.9	43	NS	NS
	High Bridge ^c	30	7.6	38	NS	NS
	Kettering ^c	33	10	42	NS	NS
	Montgomery ^c	26	12	38	NS	NS
	Piscataway ^c	39	10	49	NS	NS
	Pointer Ridge ^c	26	8	34	NS	NS
	Rosaryville Estates ^c	35	9.6	45	NS	NS
	Tantallon ^c	35	9.0	44	NS	NS
	Upper Marlboro ^c	36	10	46	NS	NS
	Woodfield ^c	34	11	44	NS	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	0.4
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	700 ^f	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

^f EPA CCL4 Health Reference Level

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
1st Quarter 2021	Potomac WFP ^a Tap	NS	NS	NS	ND	2.6
	Patuxent WFP ^a Tap	NS	NS	NS	ND	<2.0
	Accokeek ^c	27	10	36	NS	NS
	Brookeville ^c	26	10	35	NS	NS
	Cedar Heights ^c	30	11	41	NS	NS
	Central Ave ^c	19	10	28	NS	NS
	Forest Heights ^c	34	12	45	NS	NS
	Glenmont ^c	19	10	28	NS	NS
	Gwynn Park ^c	28	10	36	NS	NS
	High Bridge ^c	23	10	31	NS	NS
	Kettering ^c	25	10	34	NS	NS
	Montgomery ^c	15	9	23	NS	NS
	Piscataway ^c	23	9	31	NS	NS
	Pointer Ridge ^c	24	10	33	NS	NS
	Rosaryville Estates ^c	17	8	24	NS	NS
	Tantallon ^c	39	14	52	NS	NS
	Upper Marlboro ^c	26	10	35	NS	NS
	Woodfield ^c	27	10	36	NS	NS
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	2
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	700 ^f	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

^f EPA CCL4 Health Reference Level

Unregulated Contaminants

	Location	HAA5	HAA6Br	HAA9	1-butanol	Manganese
2nd Quarter 2021	Potomac WFP ^a Tap	NS	NS	NS	ND	14
	Patuxent WFP ^a Tap	NS	NS	NS	ND	ND
	Accokeek ^c	27	11	36	NS	NS
	Brookeville ^c	32	13	44	NS	NS
	Cedar Heights ^c	32	13	43	NS	NS
	Central Ave ^c	63	15	76	NS	NS
	Forest Heights ^c	37	13	48	NS	NS
	Glenmont ^c	60	16	74	NS	NS
	Gwynn Park ^c	34	14	46	NS	NS
	High Bridge ^c	52	15	65	NS	NS
	Kettering ^c	49	16	63	NS	NS
	Montgomery ^c	56	16	69	NS	NS
	Piscataway ^c	29	12	39	NS	NS
	Pointer Ridge ^c	49	15	62	NS	NS
	Rosaryville Estates ^c	43	15	55	NS	NS
	Tantallon ^c	30	12	40	NS	NS
	Upper Marlboro ^c	30	12	41	NS	NS
Woodfield ^c	42	16	55	NS	NS	
	<i>unit of measure</i>	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b	µg/L ^b
	<i>Minimum Reporting Level</i>	n/a	n/a	n/a	2	2
	<i>Published Health Guidance or Reference Level</i>	60 ^d	n/a	n/a	700 ^f	300 ^e

NS = Not sampled. Parameters analyzed at WFP differ than parameters analyzed at distribution sites

ND = Not detected

NOTES

^a Water treatment plant finished water sample

^b µg/L = parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million

^c Distribution sampling site

^d EPA maximum contaminant level based on highest locational running annual average

^e EPA lifetime health advisory

^f EPA CCL4 Health Reference Level