



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3084946-118-2021

MDE OFFICIAL CONTACTED: TONY SNYDER

DATA CALLED IN BY: DON O DARKO

DATE: 08/22/2021 AT 05:35PM

WORK ORDER(S): 3084946 3084942

EST DATE AND TIME SSO BEGAN: 08/22/2021 03:39PM DURATION: 3.35 HRS

DATE AND TIME SSO ENDED: 08/22/2021 07:00PM

SOURCE-OVERFLOWING MH MH08064049 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 11350 BALTIMORE AVE 20705

COUNTY/PAGE/GRID: P 5288 F04 TOWN/CITY: BELTSVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 201 GAL

UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE 049U OVERFLOWING INTO A NEARBY STORM DRAIN IN THE NORTHEAST BRANCH BASIN. THE CREW JETTED FROM MANHOLE 004U, A TOTAL OF 356 FEET, HITTING AND RELIEVING A GREASE AND WIPES OBSTRUCTION AT 288 FEET, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

DEBRIS AROUND MANHOLE 049U WAS FLUSHED BACK INTO THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 08/22/2021