



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3089204-073-2021

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: ELBE L DAVIS DATE: 09/03/2021 AT 01:40PM

WORK ORDER(S): 3089204 3089203

EST DATE AND TIME SSO BEGAN: 09/03/2021 11:16AM DURATION: 4.23 HRS
DATE AND TIME SSO ENDED: 09/03/2021 03:30PM

SOURCE-PRESSURE SEWER 00233282300 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 13530 REDGRAVE PL 20879
COUNTY/PAGE/GRID: M 4928 F03 TOWN/CITY: CLARKSBURG

CAUSE: DAMAGED BY OTHERS EST OVERFLOW VOLUME: 5 GAL
UPON ARRIVAL, WSSC WATER CREWS FOUND CONTRACTOR CORMAN CONSTRUCTION
DAMAGED A 3" PRESSURE SEWER WHICH LEAKED APPROXIMATELY 5 GALLONS
TOTAL INTO A NEARBY STORM DRAIN IN THE SENECA CREEK BASIN.
WSSC WATER CONTRACTORS REPLACED A 3 FOOT SECTION OF CONCRETE PIPE
TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
CONTRACTORS REPLACED THE BROKEN PORTION OF THE PRESSURE SEWER.
BECAUSE THE BREAK OCCURRED ON A PRESSURE SEWER, IT IS NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED ADDRESS 23000 STRINGTOWN ROAD.

SIGNS POSTED: 2 POST DATE: 09/07/2021