



NOTES:

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE.
2. DO NOT THERMITE WELD TO PVC PIPE.
3. SEE SPECIFICATION FOR ANODE SIZE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. Harner
Chief Engineer

STANDARD DETAIL
PVC AWWA C-900 PIPE
FIRE HYDRANT WITH PVC LATERAL

C
7.8