



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3092801-073-2021

MDE OFFICIAL CONTACTED: CAROL HARRELBERGER

DATA CALLED IN BY: RAVEN O YELDER

DATE: 09/29/2021 AT 08:35AM

WORK ORDER(S): 3092801 3092737

EST DATE AND TIME SSO BEGAN: 09/29/2021 06:56AM DURATION: 2.82 HRS

DATE AND TIME SSO ENDED: 09/29/2021 09:45AM

SOURCE-CLEAN OUT 00046026100 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12701 WEISS ST 20853-3461

COUNTY/PAGE/GRID: M 5165 E10 TOWN/CITY: ROCKVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 85 GAL

UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING.

THE CREW JETTED FROM MANHOLE 057M TO MANHOLE 058U, A TOTAL OF 244 FEET, RELIEVING GREASE AND WIPES AT 82 FEET, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 12700 WEISS STREET.

SIGNS POSTED: 1 POST DATE: 09/29/2021