



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3096136-073-2021

MDE OFFICIAL CONTACTED: CHRIS SHAFFNER

DATA CALLED IN BY: MARTIA D MELVIN DATE: 10/08/2021 AT 07:55AM

WORK ORDER(S): 3096136 3096124

EST DATE AND TIME SSO BEGAN: 10/08/2021 06:30AM DURATION: 0.25 HRS  
DATE AND TIME SSO ENDED: 10/08/2021 06:45AM

SOURCE-CLEAN OUT 00127094100 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 2215 CHADWICK ST 20748  
COUNTY/PAGE/GRID: P 5649 F06 TOWN/CITY: TEMPLE HILLS

CAUSE: DEBRIS EST OVERFLOW VOLUME: 2 GAL

UPON ARRIVAL, THE INSPECTOR FOUND EVIDENCE THE CLEANOUT AT THE PROPERTY LINE HAD OVERFLOWED A TOTAL OF TWO GALLONS. A WSSC WATER CONTRACT PLUMBER SNAKED FROM THE CLEANOUT, A TOTAL OF 60 FEET, RELIEVING PAPER AT 25 FEET, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME VISIBLE SOLIDS REMOVED

THE PAPER AROUND THE CLEANOUT WAS CLEANED UP.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 10/08/2021