



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3096394-118-2021

MDE OFFICIAL CONTACTED: AMANDA VON BANK

DATA CALLED IN BY: DIARRA K MACKALL DATE: 10/11/2021 AT 03:48PM

WORK ORDER(S): 3096394 3096388

EST DATE AND TIME SSO BEGAN: 10/11/2021 02:15PM DURATION: 1.42 HRS
DATE AND TIME SSO ENDED: 10/11/2021 03:40PM

SOURCE-OVERFLOWING MH MH18030087 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 2200 ANVIL LN 20748-4206
COUNTY/PAGE/GRID: P 5649 E06 TOWN/CITY: TEMPLE HILLS

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 85 GAL
UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE 087M OVERFLOWING AT A RATE OF ONE GALLON PER MINUTE INTO A STORM DRAIN IN THE OXON RUN BASIN. THE CREW JETTED FROM MANHOLE 086M, A TOTAL OF 75 FEET, RELIEVING A GREASE, WIPES, AND RAG OBSTRUCTION AT 70 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT PG COUNTY MUNICIPALITIES
MD DEPARTMENT OF ENVIRONMENT

ORIGINALLY REPORTED AS 2218 ANVIL LANE.

SIGNS POSTED: 3 POST DATE: 10/11/2021