



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3097371-118-2021

MDE OFFICIAL CONTACTED: THOMAS JOHNSON

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 10/16/2021 AT 08:25PM

WORK ORDER(S): 3097371 3097365

EST DATE AND TIME SSO BEGAN: 10/16/2021 05:39PM DURATION: 2.27 HRS  
DATE AND TIME SSO ENDED: 10/16/2021 07:55PM

SOURCE-OVERFLOWING MH MH14197105 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 6922 ST ANNES AVE 20706-3400  
COUNTY/PAGE/GRID: P 5411 D03 TOWN/CITY: LANHAM-SEABROOK

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 136 GAL  
UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE #105M OVEFLOWING AT  
A RATE OF ONE GALLON PER MINUTE. THE CREW JETTED FROM MANHOLE #106U  
THROUGH MANHOLE #105M TO MANHOLE #039U, A TOTAL OF 307 FEET,  
RELIEVING A ROOT AND GREASE OBSTRUCTION AT 278 FEET; ENDING THE  
EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME

NOTIFICATIONS MADE:  
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT  
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 7000 ST ANNES AVENUE.

SIGNS POSTED: 6 POST DATE: 10/18/2021