



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3098242-118-2021

MDE OFFICIAL CONTACTED: CHUCK RAY

DATA CALLED IN BY: RAVEN O YELDER

DATE: 10/22/2021 AT 01:31PM

WORK ORDER(S): 3098242 3098227

EST DATE AND TIME SSO BEGAN: 10/22/2021 11:53AM DURATION: 2.03 HRS

DATE AND TIME SSO ENDED: 10/22/2021 01:55PM

SOURCE-OVERFLOWING MH MH04008023 WATER BODY AFFECTED-PISCATAWAY CREEK

CLOSEST STREET ADDRESS: 3709 CHADO RD 20735-1125

COUNTY/PAGE/GRID: P 5881 K05 TOWN/CITY: CLINTON

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 609 GAL

UPON ARRIVAL, THE INSPECTOR DISCOVERED MANHOLE #023M OVERFLOWING INTO A TRIBUTARY OF PISCATAWAY CREEK, IN THE PISCATAWAY CREEK BASIN, AT A RATE OF FIVE GALLONS PER MINUTE. THE CREW JETTED FROM MANHOLE #022M, A TOTAL OF 360 FEET, RELIEVING A HEAVY GREASE AND WIPES OBSTRUCTION AT 300 FEET; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 11 POST DATE: 10/22/2021