



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3111747-118-2021

MDE OFFICIAL CONTACTED: JOSH SARCHAIPONE

DATA CALLED IN BY: DON O DARKO

DATE: 12/14/2021 AT 12:14AM

WORK ORDER(S): 3111747 3111664

EST DATE AND TIME SSO BEGAN: 12/13/2021 03:17PM DURATION: 11.22 HRS

DATE AND TIME SSO ENDED: 12/14/2021 02:30AM

SOURCE-OVERFLOWING MH MH02002191 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 3725 METZEROTT RD 20740

COUNTY/PAGE/GRID: P 5287 J10 TOWN/CITY: COLLEGE PARK

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 2,693 GAL
UPON THE INSPECTORS ARRIVAL, MANHOLE 191M WAS OVERFLOWING AT A RATE
OF 4 GALLONS PER MINUTE. THE CREW JETTED FROM MANHOLE 190M RELIEVING
A HEAVY ROOT AND GREASE OBSTRUCTION AT 100 FEET: ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

NO WATERWAY DIRECTLY AFFECTED.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 3719 METZEROTT ROAD.

SIGNS POSTED: 5 POST DATE: 12/14/2021