



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3112043-118-2021

MDE OFFICIAL CONTACTED: EVELYN STARVOU

DATA CALLED IN BY: CAROLINA GONZALEZ RUIZ DATE: 12/15/2021 AT 02:51PM

WORK ORDER(S): 3112043 3112017

EST DATE AND TIME SSO BEGAN: 12/15/2021 12:45PM DURATION: 6.75 HRS
DATE AND TIME SSO ENDED: 12/15/2021 07:30PM

SOURCE-OVERFLOWING MH MH05151038 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 5008 JASMINE DR 20853
COUNTY/PAGE/GRID: M 5165 D03 TOWN/CITY: ROCKVILLE

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 2,025 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 038M OVERFLOWING, APPROXIMATELY
5GPM INTO A NEARBY WATERWAY, IN THE ROCK CREEK BASIN. THE CREW JETTED
FROM MANHOLE 031U TO 038M, A TOTAL OF 455FT, AND RELIEVED A HARD
ROOT AND GREASE OBSTRUCTION; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION DRY WEATHER
NOTICEABLE ODOR PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

LIME WAS SPREAD ON IMPACTED GROUND AREAS.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

ORIGINALLY REPORTED AS 5201 WATERVIEW DRIVE.

SIGNS POSTED: 6 POST DATE: 12/15/2021