



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3114627-118-2022

MDE OFFICIAL CONTACTED: BRETTBOYCE/EDWARD WATSON

DATA CALLED IN BY: RAVEN O YELDER DATE: 01/01/2022 AT 04:14PM

WORK ORDER(S): 3114627 3114625

EST DATE AND TIME SSO BEGAN: 01/01/2022 02:23PM DURATION: 2.62 HRS  
DATE AND TIME SSO ENDED: 01/01/2022 05:00PM

SOURCE-OVERFLOWING MH MH05158030 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 16616 LEOPOLD TER 20855  
COUNTY/PAGE/GRID: M 5048 H10 TOWN/CITY: ROCKVILLE

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 50 GAL  
UPON ARRIVAL CREW FOUND MANHOLE 030M SURCHARGED AND EVIDENCE OF  
MANHOLE 030M HAD OVERFLOWED APPROXIMATELY 50 GALLONS TOTAL. CREW  
JETTED FROM MANHOLE 030M TO MANHOLE 021U A TOTAL OF 273 FEET AND  
RELIEVED ROOTS, GREASE AND RAGS 45 FEET DOWNSTREAM OF MANHOLE 030M  
ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
WET WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 16600 KIPLING RD

SIGNS POSTED: 2 POST DATE: 01/01/2022