



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3115251-118-2022

MDE OFFICIAL CONTACTED: KATIE BAKER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 01/06/2022 AT 03:55PM

WORK ORDER(S): 3115251 3115241

EST DATE AND TIME SSO BEGAN: 01/06/2022 02:21PM DURATION: 3.48 HRS

DATE AND TIME SSO ENDED: 01/06/2022 05:50PM

SOURCE-OVERFLOWING MH MH02044574 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 14201 BALLINGER TER 20866

COUNTY/PAGE/GRID: M 5168 A06 TOWN/CITY: BURTONSVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 60 GAL

UPON ARRIVAL, THE CREW FOUND THE MAINLINE SURCHARGED AND EVIDENCE
MANHOLE 574N AND MANHOLE 573M HAD OVERFLOWED. THE CREW JETTED FROM
MANHOLE 020U TO MANHOLE 573M 71 FEET, AND REMOVED 15 GALLONS OF ROOTS
FROM MANHOLE 573M, RELIEVING BLOCKAGE.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

THE AREA WAS RAKED, AND LIME WAS SPREAD IN THE AREA OF BOTH MANHOLES.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 6 POST DATE: 01/06/2022