



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3114492-109-2021

MDE OFFICIAL CONTACTED: KATIE BAKER

DATA CALLED IN BY: RAVEN O YELDER

DATE: 12/30/2021 AT 02:55PM

WORK ORDER(S): 3114492 3114479

EST DATE AND TIME SSO BEGAN: 12/30/2021 01:09PM DURATION: 3.35 HRS

DATE AND TIME SSO ENDED: 12/30/2021 04:30PM

SOURCE-REPAIR SEWER MAIN SS20006030 WATER BODY AFFECTED-POTOMAC RIVER

CLOSEST STREET ADDRESS: 10420 MASTERS TER 20854

COUNTY/PAGE/GRID: M 5405 F03 TOWN/CITY: ROCKVILLE

CAUSE: STREAM EROSION EST OVERFLOW VOLUME: 302 GAL
PER CONTRACT MANAGER, PIPE WAS EXPOSED IN DRAINAGE DITCH AND OVERFLOWED INTO
A WOODED AREA. A CONTRACTOR TO CUT OUT BROKEN SECTION OF PIPE AND
INSTALLED 30 FEET OF 8 INCH PVC PIPE WHICH ENDED THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

BROKEN PIPE HAS BEEN REPLACED.

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

VISIBLE SOLIDS REMOVED

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 3 POST DATE: 01/03/2022