



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3121218-118-2022

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 02/02/2022 AT 02:58PM

WORK ORDER(S): 3121218 3121202

EST DATE AND TIME SSO BEGAN: 02/02/2022 01:59PM DURATION: 3.27 HRS
DATE AND TIME SSO ENDED: 02/02/2022 05:15PM

SOURCE-OVERFLOWING MH MH05004017 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 2801-23 TERRACE DR 20815
COUNTY/PAGE/GRID: M 5408 A01 TOWN/CITY: CHEVY CHASE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 589 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 017M OVERFLOWING APPROXIMATELY
3GPM INTO A NEARBY CREEK; IN THE ROCK CREEK BASIN. THE CREW JETTED
FROM MANHOLE 017M TO 009U A TOTAL OF 346FT, AND RELIEVED A
HEAVY GREASE AND WIPES BLOCKAGE AT 300FT; ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

TWO BAGS OF LIME WAS APPLIED 02/02/2022; TWO MORE WILL BE APPLIED AFTER
THE RAIN PER N.GROSS.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

ORIGINALLY REPORTED AS 2800 TERRACE DR

SIGNS POSTED: 8 POST DATE: 02/02/2022