



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3121639-118-2022

MDE OFFICIAL CONTACTED: HOLLY

DATA CALLED IN BY: KIMBERLY M B GILLIS DATE: 02/05/2022 AT 11:45PM

WORK ORDER(S): 3121639 3121632

EST DATE AND TIME SSO BEGAN: 02/05/2022 03:48PM DURATION: 2.70 HRS
DATE AND TIME SSO ENDED: 02/05/2022 06:30PM

SOURCE-OVERFLOWING MH MH10020063 WATER BODY AFFECTED-NORTHWEST BRANCH

CLOSEST STREET ADDRESS: 1355 E UNIVERSITY BLVD 20912
COUNTY/PAGE/GRID: M 5286 E05 TOWN/CITY: TAKOMA PARK

CAUSE: GREASE EST OVERFLOW VOLUME: 162 GAL
UPON ARRIVAL MANHOLE 063M WAS OVERFLOWING APPROXIMATELY 1GPM AND
ENTERING INTO A NEARBY STORM DRAIN, IN THE NORTHWEST BRANCH BASIN.
THE CREW JETTED FROM MANHOLE 062M A TOTAL OF 414FT, AND RELIEVED
HEAVY GREASE BLOCKAGES AT 15FT AND 240FT; ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NOTICEABLE ODOR PUBLIC ACCESS
PUBLIC USE OBSERVED DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA

FLUSHED AND SALTED SIDEWALK AND CURBLINE.

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY MONTGOMERY CO MUNICIPALITIES
MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 1 POST DATE: 02/06/2022