



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3121784-118-2022

MDE OFFICIAL CONTACTED: PAUL SCHLETTERBECK

DATA CALLED IN BY: ELBE L DAVIS

DATE: 02/07/2022 AT 10:35AM

WORK ORDER(S): 3121784 3121763

EST DATE AND TIME SSO BEGAN: 02/07/2022 08:58AM DURATION: 2.53 HRS

DATE AND TIME SSO ENDED: 02/07/2022 11:30AM

SOURCE-OVERFLOWING MH MH08037060 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 5901 WESTCHESTER PK DR 20740

COUNTY/PAGE/GRID: P 5410 F02 TOWN/CITY: COLLEGE PARK

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 455 GAL

UPON ARRIVAL THE CREW FOUND MANHOLE 060M OVERFLOWING. THE CREW JETTED FROM MANHOLE 059M TO 060M A TOTAL OF 200FT, AND RELIEVED A GREASE AND ROOTS OBSTRUCTION AT 140FT; ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

ONE BAG OF LIME AND ONE BAIL OF HAY WILL BE USED TO TREAT AREA OF OVERFLOW.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

SIGNS POSTED: 5 POST DATE: 02/07/2022